



From: Yancey, Gary
To: James R. Dowling
Cc: Shonk,Brian; Checkley, Mia; Jones,Sam; Stein, Melinda
Subject: RE: NWF State College - Special Purpose Building - Destin

Sent: Thu 12/4/2008 10:36 AM

OK, thanks. These are not huge budget issues are they?

From: James R. Dowling [mailto:jdowning@kddarchitects.com]
Sent: Thursday, December 04, 2008 8:53 AM
To: Yancey, Gary
Cc: Shonk,Brian; Checkley, Mia; Jones,Sam; Stein, Melinda
Subject: NWF State College - Special Purpose Building - Destin

We have it confirmed by the user of the Staging area that multiple aircraft will be stored, therefore we are required to add floor trench drains, slope the floor, and add a gas intercept in the line by code.

James R. Dowling, AIA, President
Kendrick David Dowling Architects Inc.
111 Ferry Road SE, Suite A
Ft. Walton Beach, Florida 32548
Ph: 850-243-9158
Fax: 850-664-2374